

CERTIFICATE OF COMPLIANCE

Certificate Number EX26893
Report Reference EX26893-20151117
Date 2021-February-12

Issued to: TOSCELIK PROFIL VE SAC ENDUSTRISI A.S
Buyuktuysuz Mah. Ali Ilbeyli Cad. No:10
Tuysuz
ToprakkaleOsmaniye 80950 TR

This is to certify that representative samples of METALLIC SPRINKLER PIPE
See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL 852, Metallic Sprinkler Pipe for Fire Protection Service
ULC/ORD C199S, Light Wall Steel Pipes for Sprinkler Systems for Fire Protection Service

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number EX26893
Report Reference EX26893-20151117
Date 2021-February-12

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Metallic Sprinkler Pipe

Steel Sprinkler Pipe for wet, dry, preaction and deluge type sprinkler systems with unthreaded ends intended to be joined by welding or Listed Rubber Gasketed Fittings when installed in accordance with the fitting manufacturer's specifications.

Schedule 10 pipe in the 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5, 6, 8, and 10 inch sizes


Schedule 30 steel pipe in the 8, 10 and 12 inch sizes

Schedule 40 steel pipe in the 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5, 6, 8, 10 and 12 inch sizes

Schedule 80 steel pipe in the 3/4, 1, 1-1/4, 1-1/2, 2, 3, 3-1/2, 4, 5, 6 and 8 inch sizes

Weight Class STD steel pipe in the 12 inch sizes

0.188 in. Wall Thickness Steel Pipe in the 5, 6, 8 and 10 inch sizes



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

